

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. Contract Number		Page of Pages 1 of 3	
2. Amendment/Modification Number No. 3		3. Effective Date See Block 16C		4. Requisition/Purchase Request No.		5. Solicitation Caption: Reconstruction of Q Street NW from 14th St. To 11th St.	
6. Issued By: Department of Transportation Construction Contract Branch 2000 14th Street, NW, 6th Floor Washington, DC 20009				7. Administered By (If other than line 6) Procurement Support Branch 2000 14th Street, NW, 3rd Floor Bid Room Washington, DC 20009			
8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)				(X)		9A. Amendment of Solicitation No. POKA-2006-B-0095-JJ	
						9B. Dated (See Item 11) 8/16/2006	
						10A. Modification of Contract/Order No.	
						10B. Dated (See Item 13)	
Code		Facility					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
X The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended. <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning 2 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. Accounting and Appropriation Data (If Required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14							
A. This change order is issued pursuant to: (Specify Authority)							
The changes set forth in Item 14 are made in the contract/order no. in item 10A.							
B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.							
C. This supplemental agreement is entered into pursuant to authority of:							
D. Other (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return 2 copies to the issuing office.							
14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.)							
<p>The current bid opening date of September 20, 2006 is extended</p> <p><u>The purpose of this Amendment is to respond to additional questions/comments from prospective bidders (2 pages attached) and to extend the bid opening date.</u></p> <p>The bid opening date has been extended from September 20, 2006 to September 22, 2006 Office of Contracting and Procurement Bid Room 2000 14th Street NW, 3rd Floor Washington, DC 20009 Bids will open at 2:00 p.m.</p> <p>NO ADDITIONAL QUESTIONS WILL BE ACCEPTED PER ISSUANCE OF THIS AMENDMENT.</p>							
Except as provided herein, all terms and conditions of the document referenced in Item (9A or 10A) remain unchanged and in full force and effect							
15A. Name and Title of Signer (Type or print)				16A. Name of Contracting Officer Jerry M. Carter			
15B. Name of Contractor		15C. Date Signed		16B. District of Columbia		16C. Date Signed 9/15/2006	
(Signature of person authorized to sign)				(Signature of Contracting Officer)			

POKA-2006-B-0095-JJ
Reconstruction of Q Street NW from 14th Street to 11th Street NW

Additional Questions/Responses

Question-1 Sheet 72(of 111) indicates the run from Manhole M1 to the existing PEPCO manhole is to be 2-4" PVC conduits. Drawing Note #4 (same sheet#) Says 4-4" conduits. Which is correct? (same question for sheet 75, manhole M14)

Response 1: 4-4" Conduits is correct.

Question-2 Bid Item Line 0030 states to "Furnish and Install Type A Pole". There are no specs or

drawings for a "type A" pole. What is it? Same question for Line 0050 "Type A Luminaire".

Response 2: Item descriptions for the items against Line Nos. 0030 as well as 0050 are revised.

Line 0030 description should read as follows:

000506 Unassigned Special Item-EACH-
618 487 – FURNISH AND INSTALL POLES, PENDANT.

Line 0050 description should read as follows:

000506 Unassigned Special Item – EACH –
618 725 - FURNISH AND INSTALL LUMINAIRE,
CUTOFF HPS 400 WATTS

Question 3 Do line items 0070 through 0100 refer only to the dry-mix or do they include the conduit?

Response 3: Yes . Only to the dry mix.

Question 4 Should Line Item 1260 read "4/0" rather than "4"?

Response 4 : Yes. Should read 4/0.

Question 5 Should Line Item 1020 read "stranded" rather than "standard"?

Response 5 : Yes, should read Stranded

Question 6 Why are there no real specifications on this project? The spec book is just full of drawings and standards, many of which have no relevance to the project.

Response 6: Specifications on this Project are mentioned in the Contract Documents.

Question 7 Will there be a Pre-Bid meeting for this project?

Response 7: Pre-Bid meeting was on September 7, 2006 and was announced via Amendment No. 1